

| | A | B | C | D | E | F | G | H | I | J | K | L | M | N | O |
|----|----------------------------------|---------------------------|-------------------|--------------------|-------------------|---------------------|---------------------|-----------------------|------------------------|------------------------|------------------------|-------------------------|-----------------------|----------------------|---------------------|
| 1 | Toplotna bilanca celica 1 | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | |
| 3 | N1 | Klet | | | | | | | | | | | | | |
| 4 | P | Prostor | A (m²) | tn (°C) | Qn (W) | PhiT (W) | PhiV (W) | Phi RH (W) | Qi(dvo) (W) | Qi(eno) (W) | Qi(tal) (W) | Qi(sten) (W) | Qi(vk) (W) | Qinst (W) | Qost (W) |
| 5 | P1 | Celica 1 K.08 | 88 | 20 | 1008 | 872 | 136 | 0 | 1227 | 0 | 0 | 0 | 0 | ### | 219 |
| 6 | P2 | C1-Prostor1 K.10 | 2 | 20 | 21 | 7 | 14 | 0 | 131 | 0 | 0 | 0 | 0 | 131 | 110 |
| 7 | P3 | C1-Stopnišče K.09 | 11 | 20 | 73 | 32 | 41 | 0 | 190 | 0 | 0 | 0 | 0 | 190 | 117 |
| 8 | P4 | C1-Prostor2 K.11 | 5 | 20 | 72 | 58 | 14 | 0 | 131 | 0 | 0 | 0 | 0 | 131 | 59 |
| 9 | | Skupno: Klet | | | 1174 | 969 | 205 | 0 | 1679 | 0 | 0 | 0 | 0 | ## | ## |
| 10 | | | | | | | | | | | | | | | |
| 11 | N2 | Pritličje | | | | | | | | | | | | | |
| 12 | P | Prostor | A (m²) | tn (°C) | Qn (W) | PhiT (W) | PhiV (W) | Phi RH (W) | Qi(dvo) (W) | Qi(eno) (W) | Qi(tal) (W) | Qi(sten) (W) | Qi(vk) (W) | Qinst (W) | Qost (W) |
| 13 | P1 | Celica 1 P.07 - dvoetažna | 120 | 20 | 2026 | 1686 | 340 | 0 | 2264 | 0 | 0 | 0 | 0 | ### | 238 |
| 14 | P2 | C1 - WC P.10 | 3 | 20 | 20 | 0 | 20 | 0 | 131 | 0 | 0 | 0 | 0 | 131 | 111 |
| 15 | P3 | C1 - Čistila P.09 | 1 | 20 | 14 | 0 | 14 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -14 |
| 16 | P4 | C1 - Stopnišče P.08 | 11 | 20 | 41 | 0 | 41 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -41 |
| 17 | P5 | C1 - Čajna kuhinja P.11 | 6 | 20 | 31 | 0 | 31 | 0 | 131 | 0 | 0 | 0 | 0 | 131 | 100 |
| 18 | P6 | C1 - Garderoba | 7 | 20 | 31 | 0 | 31 | 0 | 131 | 0 | 0 | 0 | 0 | 131 | 100 |
| 19 | | Skupno: Pritličje | | | 2163 | 1686 | 477 | 0 | 2657 | 0 | 0 | 0 | 0 | ## | ## |
| 20 | | | | | | | | | | | | | | | |
| 21 | N3 | Medetaža | | | | | | | | | | | | | |
| 22 | P | Prostor | A (m²) | tn (°C) | Qn (W) | PhiT (W) | PhiV (W) | Phi RH (W) | Qi(dvo) (W) | Qi(eno) (W) | Qi(tal) (W) | Qi(sten) (W) | Qi(vk) (W) | Qinst (W) | Qost (W) |
| 23 | P1 | C1 - WC ME.19 | 3 | 20 | 20 | 0 | 20 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -20 |
| 24 | P2 | C1 - Podest s stop. ME.18 | 25 | 20 | 75 | 0 | 75 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -75 |
| 25 | P3 | C1 - Čajna kuh. ME.21 | 2 | 20 | 35 | 4 | 31 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -35 |
| 26 | P4 | C1 - Pisarna 1 | 10 | 20 | 38 | 7 | 31 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -38 |
| 27 | P5 | C1 - Pisarna 2 | 12 | 20 | 38 | 7 | 31 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -38 |
| 28 | | Skupno: | | | 206 | 18 | 188 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | ## |
| 29 | | | | | | | | | | | | | | | |
| 30 | | Skupno: | | | 3543 | 2673 | 870 | 0 | 4336 | 0 | 0 | 0 | 0 | ## | ## |