

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	<b>Toplotna bilanca Prostor i KI</b>														
2															
3	<b>N4</b>	<b>Klet</b>													
4	<b>P</b>	<b>Prostor</b>	<b>A (m²)</b>	<b>tn (°C)</b>	<b>Qn (W)</b>	<b>PhiT (W)</b>	<b>PhiV (W)</b>	<b>Phi RH (W)</b>	<b>Qi(dvo) (W)</b>	<b>Qi(eno) (W)</b>	<b>Qi(tal) (W)</b>	<b>Qi(sten) (W)</b>	<b>Qi(vk) (W)</b>	<b>Qi nst</b>	<b>Qo st</b>
5	P1	Stopnišče K.06	16	20	158	124	34	0	259	0	0	0	0	259	101
6	P30	Tehnični p. 1 K.02	51	20	669	533	136	0	674	0	0	0	0	674	5
7	P31	Tehnični p. 1 K.02a	13	20	179	138	41	0	259	0	0	0	0	259	80
8	P32	Skladišče biomase/odpadki	50	20	668	430	238	0	674	0	0	0	0	674	6
9	P33	Procesna hala K.01	147	20	2169	1353	816	0	2264	0	0	0	0	###	95
10	P35	Tehnični p. 3 K.04	50	20	505	369	136	0	518	0	0	0	0	518	13
11	P36	Strojnica rez. osmoze	25	20	610	542	68	0	674	0	0	0	0	674	64
12		<b>Skupno: Klet</b>			<b>4958</b>	<b>3489</b>	<b>1469</b>	<b>0</b>	<b>5322</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>##</b>	<b>##</b>
13															
14	<b>N6</b>	<b>Pritličje</b>													
15	<b>P</b>	<b>Prostor</b>	<b>A (m²)</b>	<b>tn (°C)</b>	<b>Qn (W)</b>	<b>PhiT (W)</b>	<b>PhiV (W)</b>	<b>Phi RH (W)</b>	<b>Qi(dvo) (W)</b>	<b>Qi(eno) (W)</b>	<b>Qi(tal) (W)</b>	<b>Qi(sten) (W)</b>	<b>Qi(vk) (W)</b>	<b>Qi nst</b>	<b>Qo st</b>
16	P1	Vetrolov P.01	6	15	166	166	0	0	0	0	0	0	0	0	###
17	P2	Vhodna avla P.02	24	20	48	0	48	0	0	0	0	0	0	0	-48
18	P3	Sanitarije M P.03	5	20	41	0	41	0	0	0	0	0	0	0	-41
19	P4	Sanitarije Ž P.04	6	20	118	77	41	0	0	0	0	0	0	0	###
20	P5	Stopnišče P.05	16	20	0	0	0	0	0	0	0	0	0	0	0
21	P6	Predavalnica	66	20	824	144	680	0	0	0	0	0	0	0	###
22		<b>Skupno: Pritličje</b>			<b>1197</b>	<b>387</b>	<b>810</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>##</b>
23															
24	<b>N7</b>	<b>Medetaža</b>													
25	<b>P</b>	<b>Prostor</b>	<b>A (m²)</b>	<b>tn (°C)</b>	<b>Qn (W)</b>	<b>PhiT (W)</b>	<b>PhiV (W)</b>	<b>Phi RH (W)</b>	<b>Qi(dvo) (W)</b>	<b>Qi(eno) (W)</b>	<b>Qi(tal) (W)</b>	<b>Qi(sten) (W)</b>	<b>Qi(vk) (W)</b>	<b>Qi nst</b>	<b>Qo st</b>
26	P2	Stopnišče ME.01	16	20	68	0	68	0	0	0	0	0	0	0	-68
27	P3	Hodnik ME.02	44	20	156	0	156	0	0	0	0	0	0	0	###
28	P4	Čajna kuhinja ME.03	8	20	41	0	41	0	0	0	0	0	0	0	-41
29	P5	Predprostor ME.04	3	20	165	151	14	0	0	0	0	0	0	0	###
30	P6	Sanitarije M ME.05	4	20	41	0	41	0	0	0	0	0	0	0	-41
31	P7	Sanitarije Ž ME.06	3	20	41	0	41	0	0	0	0	0	0	0	-41
32	P8	TUŠ ME.07a	3	20	41	0	41	0	0	0	0	0	0	0	-41
33	P9	Čistila ME.07	2	20	20	0	20	0	0	0	0	0	0	0	-20
34	P10	Skladišče ME.08	3	20	41	0	41	0	0	0	0	0	0	0	-41
35	P11	Sejna soba ME.09	17	20	204	0	204	0	0	0	0	0	0	0	###
36	P12	Pisarna1 ME.10	19	20	409	327	82	0	0	0	0	0	0	0	###
37	P13	Pisarna2 ME.11	12	20	295	247	48	0	0	0	0	0	0	0	###
38	P14	Pisarna3 ME.12	11	20	311	263	48	0	0	0	0	0	0	0	###
39	P15	Pisarna4 ME.13	16	20	775	727	48	0	0	0	0	0	0	0	###
40	P16	Pisarna5 ME.14	15	20	281	220	61	0	0	0	0	0	0	0	###
41	P17	Laboratorij1 ME.15	29	20	923	841	82	0	0	0	0	0	0	0	###
42	P18	Laboratorij2 ME.16	20	20	396	335	61	0	0	0	0	0	0	0	###
43	P19	Laboratorij3 ME.17	33	20	649	567	82	0	0	0	0	0	0	0	###
44		<b>Skupno:</b>			<b>4857</b>	<b>3678</b>	<b>1179</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>##</b>
45															
46		<b>Skupno:</b>			<b>11012</b>	<b>7554</b>	<b>3458</b>	<b>0</b>	<b>5322</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>##</b>	<b>##</b>