

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Toplotna bilanca Celica 4														
2															
3	N1	Klet													
	P	Prostor	A (m²)	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Phi RH (W)	Qi(dvo) (W)	Qi(eno) (W)	Qi(tal) (W)	Qi(sten) (W)	Qi(vk) (W)	Qi nst	Qo st
4	P1	Celica 4 K.21	81	20	981	845	136	0	0	0	0	0	0	0	###
5	P2	C4-Prostor2 K.24	3	20	23	9	14	0	0	0	0	0	0	0	-23
6	P3	C4-Stopnišče K.22	12	20	59	32	27	0	0	0	0	0	0	0	-59
7	P4	C4-Prostor1 K.23	5	20	28	14	14	0	0	0	0	0	0	0	-28
8	P5	C4-Prostor 3 K.25	8	20	106	92	14	0	0	0	0	0	0	0	###
9		Skupno: Klet			1197	992	205	0	0	0	0	0	0	0	##
10															
11															
12	N2	Pritličje													
	P	Prostor	A (m²)	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Phi RH (W)	Qi(dvo) (W)	Qi(eno) (W)	Qi(tal) (W)	Qi(sten) (W)	Qi(vk) (W)	Qi nst	Qo st
13	P1	Celica 4 P.25 - dvoetažna	125	20	2110	1770	340	0	0	0	0	0	0	0	###
14	P2	C4 - WC P.28	3	20	20	0	20	0	0	0	0	0	0	0	-20
15	P3	C4 - Čistila P.27	4	20	14	0	14	0	0	0	0	0	0	0	-14
16	P4	C4 - Stopnišče P.26	12	20	14	0	14	0	0	0	0	0	0	0	-14
17	P5	C4 - Čajna kuhinja P.29	7	20	31	0	31	0	0	0	0	0	0	0	-31
18	P6	C4 - Garderoba	7	20	31	0	31	0	0	0	0	0	0	0	-31
19		Skupno: Pritličje			2220	1770	450	0	0	0	0	0	0	0	##
20															
21															
22	N3	Medetaža													
	P	Prostor	A (m²)	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Phi RH (W)	Qi(dvo) (W)	Qi(eno) (W)	Qi(tal) (W)	Qi(sten) (W)	Qi(vk) (W)	Qi nst	Qo st
23	P1	C4 - WC ME.34	3	20	20	0	20	0	0	0	0	0	0	0	-20
24	P2	C4 - Podest s stop. ME.33	20	20	162	87	75	0	0	0	0	0	0	0	###
25	P3	C4 - Čajna kuh. ME.36	2	20	38	7	31	0	0	0	0	0	0	0	-38
26	P4	C4 - Pisarna 1	8	20	55	24	31	0	0	0	0	0	0	0	-55
27	P5	C4 - Pisarna 2	9	20	72	41	31	0	0	0	0	0	0	0	-72
28		Skupno:			347	159	188	0	0	0	0	0	0	0	##
29															
30															
31		Skupno:			3764	2921	843	0	0	0	0	0	0	0	##