

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Toplotna bilanca Inkubator JUG														
2															
3	N4	Pritličje - nadstropje													
	P	Prostor	A (m²)	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Phi RH (W)	Qi(dvo) (W)	Qi(eno) (W)	Qi(tal) (W)	Qi(sten) (W)	Qi(vk) (W)	Qi nst	Qi st
4	P1	Vhodna avla	60	20	3216	2944	272	0	0	0	0	0	0	0	###
5	P2	Vezni hodnik	74	20	211	177	34	0	0	0	0	0	0	0	###
6		Skupno: Pritličje - nadstropje			3427	3121	306	0	0	0	0	0	0	0	##
7															
8															
9	N5	Nadstropje													
	P	Prostor	A (m²)	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Phi RH (W)	Qi(dvo) (W)	Qi(eno) (W)	Qi(tal) (W)	Qi(sten) (W)	Qi(vk) (W)	Qi nst	Qi st
10	P1	Sejna soba 1	30	20	1869	1733	136	0	0	0	0	0	0	0	###
11	P2	Sejna soba 2	36	20	2164	2028	136	0	0	0	0	0	0	0	###
12	P3	Sejna soba 3	29	20	1856	1720	136	0	0	0	0	0	0	0	###
13	P4	Avla	296	20	2889	2379	510	0	0	0	0	0	0	0	###
14	P5	Večnamenska dvorana	126	20	3416	2532	884	0	0	0	0	0	0	0	###
15	P6	Čajna kuhinja	9	20	89	38	51	0	0	0	0	0	0	0	-89
16	P7	Teh.p.	20	20	181	164	17	0	0	0	0	0	0	0	###
17	P8	Čistila	3	20	22	12	10	0	0	0	0	0	0	0	-22
18	P9	WC invalidi	6	20	55	24	31	0	0	0	0	0	0	0	-55
19	P10	WC moški	10	20	124	42	82	0	0	0	0	0	0	0	###
20	P11	WC ženske	14	20	503	421	82	0	0	0	0	0	0	0	###
21		Skupno:			13168	11093	2075	0	0	0	0	0	0	0	##
22															
23															
24		Skupno:			16595	14214	2381	0	0	0	0	0	0	0	##